

MARNHULL VILLAGE HALL FIRE RISK ASSESSMENT

Completed by: Steve Finch		Date completed: 12012021		
LOCATION	SOURCES OF FUEL/ IGNITION	FIRE FIGHTING & EQUIPMENT	ESCAPE ROUTES	EMERGENCY LIGHTING SIGNS & EQUIPMENT
1. MAIN ENTRANCE	Electric lights	1 x Fire Alarm activation button	Via main door or out through main hall emergency exit	Audible fire alarm Location of emergency exits signed and lit Emergency lighting
2. MAIN HALL	Electric sockets and lighting Stage lighting Audio/visual equipment Chairs Tables	Fire Extinguishers: 1 x Water 1 x Foam 1 x CO2 1 x Fire Alarm activation button	Via main door Via emergency exit in the main hall Via emergency exit in Bar area	Audible fire alarm Location of emergency exits signed and lit Emergency lighting
3. MAIN TOILETS	Electric lighting	None	Via main door Via emergency exit in the main hall	Audible fire alarm Emergency lighting
4. STAGE	Electric sockets and lighting Audio/visual system. Flood Lights Stage Drapes and scenery used as props Flammable substances must either be replaced or when this is impossible measures taken to control the risk. Scenery and fabrics for use on stage must be rendered non-flammable by treatment during manufacture. Proprietary materials must comply with industry standards for fireproofing eg. hardboard and plywood must have a "Class 1 impregnated to BS476" stamped on it. Storage of combustible material near a source of ignition is not permitted <u>WILL NEED TO SORTED</u>	None	Via exits on either side of the stage Via main door Via emergency exit in the main hall	Audible fire alarm Location of emergency exits signed & lit

5. KITCHEN	Electric cooker/oven Electric sockets and lighting. Dish washer Kettle Urn Microwave Fridge Freezer	1 x CO2 extinguisher 1 x Fire Blanket	Via emergency exit adjacent to kitchen. Via main hall emergency exit	Audible fire alarm Main power on/off fob by door “Turn off” sign for urn
6. POWER Plant ROOM	Main Electrical supply Gas boiler for heating & water Electric sockets and lighting	1 x Foam extinguisher	Via main door Via emergency exit in the main hall Via emergency exit in Bar area	Audible Fire alarm
7. STORAGE AREAS	Electric sockets and lighting Stored cushioned seats	None	Via main door Via emergency exit in the main hall	Audible Fire alarm
8. Original LADIES TOILETS	Electric lighting	None	Via emergency exit in the main hall Via side entrance Via Pavilion exit	Audible Fire alarm
9. PAVILION	Electric lighting and sockets. Electric insect catcher Electric Fridge Kettle	1 x Foam Extinguisher	Through Pavilion doors whilst room is in use. Via side entrance	Audible Fire alarm
10. CHANGING ROOMS	Electric lighting The main incoming electricity board in the away dressing-room PVS inverter, contact-breaker and meter	None	Via only door onto the field	Exit signs